SYSMAC CS and CJ Series

CS1W-EIP21S (100Base-TX) CJ1W-EIP21S (100Base-TX)

EtherNet/IP[™] Units Firmware Update

USER'S MANUAL

OMRON

- NOTE -

- 1. All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form, or by any means, mechanical, electronic, photocopying, recording, or otherwise, without the prior written permission of OMRON.
- 2. No patent liability is assumed with respect to the use of the information contained herein.

 Moreover, because OMRON is constantly striving to improve its high-quality products, the information contained in this manual is subject to change without notice.
- 3. Every precaution has been taken in the preparation of this manual. Nevertheless, OMRON assumes no responsibility for errors or omissions.

Neither is any liability assumed for damages resulting from the use of the information contained in this publication.

- Trademarks -

- SYSMAC is a registered trademark for Programmable Controllers made by OMRON Corporation.
- CX-One is a registered trademark for Programming Software made by OMRON Corporation.
- Sysmac and SYSMAC are trademarks or registered trademarks of OMRON Corporation in Japan and other countries for OMRON factory automation products.
- Microsoft, Windows, Excel, Visual Basic, and Microsoft Edge are either registered trademarks or trademarks of Microsoft Corporation in the United States and other countries.
- EtherCAT® is registered trademark and patented technology, licensed by Beckhoff Automation GmbH, Germany.
- ODVA, CIP, CompoNet, DeviceNet, and EtherNet/IP are trademarks of ODVA.

Other company names and product names in this document are the trademarks or registered trademarks of their respective companies.

Copyrights

- Microsoft product screen shots used with permission from Microsoft.
- This product incorporates certain third party software. The license and copyright information associated with this software is available at http://www.fa.omron.co.jp/nj_info_e/.

Introduction

Thank you for purchasing a CS/CJ-series EtherNet/IP Unit.

This manual contains information that is necessary to update the firmware of CS/CJ-series EtherNet/IP Unit.

Please read this manual and make sure you understand the firmware update before you attempt to use it in a control system.

Keep this manual in a safe place where it will be available for reference during operation.

Intended Audience

This manual is intended for the following personnel, who must also have knowledge of electrical systems (an electrical engineer or the equivalent).

- · Personnel in charge of introducing FA systems.
- · Personnel in charge of designing FA systems.
- · Personnel in charge of installing and maintaining FA systems.
- · Personnel in charge of managing FA systems and facilities.

Note that this manual is intended for those who have a knowledge of the CS/CJ-series PLCs and experience in designing equipment that uses the products.

Applicable Products

This manual covers the following products.

CJ Series

• CJ1W-EIP21S


CS Series

CS1W-EIP21S

Manual Structure

Page Structure

The following page structure is used in this manual.



Note This illustration is provided only as a sample. It may not literally appear in this manual.

Special Information

Special information in this manual is classified as follows:



Precautions for Safe Use

Precautions on what to do and what not to do to ensure safe usage of the product.



Precautions for Correct Use

Precautions on what to do and what not to do to ensure proper operation and performance.



Additional Information

Additional information to read as required.

This information is provided to increase understanding or make operation easier.



Version Information

Information on differences in specifications and functionality for applicable products with different unit versions and for different versions of the Support Software is given.

Manual Structure

Sections in this Manual

1 Advance Preparations

2 Performing Firmware Update

3 Troubleshooting

A Appendices

I Index

CONTENTS

	Introduction	1
	Intended Audience	
	Applicable Products	I
	Manual Structure	2
	Page Structure	
	Special Information	3
	Sections in this Manual	5
	Terms and Conditions Agreement	
	Warranty, Limitations of Liability	
	Application Considerations	
	Statement of security responsibilities for assumed use cases and against threats	
	Safety Precautions	11
	Precautions for Safe Use	12
	Precautions for Correct Use	13
	Versions	14
	Related Manuals	
	Related Mailuais	19
	Revision History	16
Secti	ion 1 Advance Preparations	
Secti	ion 1 Advance Preparations 1-1 Preparations	1-2
Secti	<u> </u>	
Secti	1-1 Preparations	1-3
Secti	1-1 Preparations	1-3 1-5
Secti	1-1 Preparations	1-3 1-5
Secti Secti	1-1 Preparations	1-3 1-5
	1-1 Preparations	1-3 1-5 1-6
	1-1 Preparations	1-3 1-5 1-6
	1-1 Preparations	1-3 1-5 1-6 2-2
	1-1 Preparations	1-31-51-62-22-3
	1-1 Preparations	1-31-52-22-22-3
Secti	1-1 Preparations	1-31-52-22-22-3
	1-1 Preparations	1-31-52-22-22-32-8
Secti	1-1 Preparations	1-31-51-62-22-32-42-8

	3	3-2-2 Errors during Restart after Update	3-6
Apper	ndic	es	
	A-1	Installing and Uninstalling the EIP21S Firmware Update Tool	A-2
	A-2	Operation Log	A-3
Index			

Terms and Conditions Agreement

Warranty, Limitations of Liability

Warranties

Exclusive Warranty

Omron's exclusive warranty is that the Products will be free from defects in materials and work-manship for a period of twelve months from the date of sale by Omron (or such other period expressed in writing by Omron). Omron disclaims all other warranties, express or implied.

Limitations

OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, ABOUT NON-INFRINGEMENT, MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE PRODUCTS. BUYER ACKNOWLEDGES THAT IT ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE.

Omron further disclaims all warranties and responsibility of any type for claims or expenses based on infringement by the Products or otherwise of any intellectual property right.

Buyer Remedy

Omron's sole obligation hereunder shall be, at Omron's election, to (i) replace (in the form originally shipped with Buyer responsible for labor charges for removal or replacement thereof) the non-complying Product, (ii) repair the non-complying Product, or (iii) repay or credit Buyer an amount equal to the purchase price of the non-complying Product; provided that in no event shall Omron be responsible for warranty, repair, indemnity or any other claims or expenses regarding the Products unless Omron's analysis confirms that the Products were properly handled, stored, installed and maintained and not subject to contamination, abuse, misuse or inappropriate modification. Return of any Products by Buyer must be approved in writing by Omron before shipment. Omron Companies shall not be liable for the suitability or unsuitability or the results from the use of Products in combination with any electrical or electronic components, circuits, system assemblies or any other materials or substances or environments. Any advice, recommendations or information given orally or in writing, are not to be construed as an amendment or addition to the above warranty.

See http://www.omron.com/global/ or contact your Omron representative for published information.

Limitation on Liability; Etc

OMRON COMPANIES SHALL NOT BE LIABLE FOR SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR PRODUCTION OR COMMERCIAL LOSS IN ANY

WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED IN CONTRACT, WARRANTY, NEGLIGENCE OR STRICT LIABILITY.

OMRON SHALL NOT BE RESPONSIBLE AND/OR LIABLE FOR ANY LOSS, DAMAGE, OR EXPENSES DIRECTLY OR INDIRECTLY RESULTING FROM THE INFECTION OF OMRON PRODUCTS, ANY SOFTWARE INSTALLED THEREON OR ANY COMPUTER EQUIPMENT, COMPUTER PROGRAMS, NETWORKS, DATABASES OR OTHER PROPRIETARY MATERIAL CONNECTED THERETO BY DISTRIBUTED DENIAL OF SERVICE ATTACK, COMPUTER VIRUSES, OTHER TECHNOLOGICALLY HARMFUL MATERIAL AND/OR UNAUTHORIZED ACCESS.

It shall be the users sole responsibility to determine and use adequate measures and checkpoints to satisfy the users particular requirements for (i) antivirus protection, (ii) data input and output, (iii) maintaining a means for reconstruction of lost data, (iv) preventing Omron Products and/or software installed thereon from being infected with computer viruses and (v) protecting Omron Products from unauthorized access.

Further, in no event shall liability of Omron Companies exceed the individual price of the Product on which liability is asserted.

Application Considerations

Suitability of Use

Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT(S) IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

Programmable Products

Omron Companies shall not be responsible for the user's programming of a programmable Product, or any consequence thereof.

Disclaimers

Performance Data

Data presented in Omron Company websites, catalogs and other materials is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of Omron's test conditions, and the user must correlate it to actual application requirements. Actual performance is subject to the Omron's Warranty and Limitations of Liability.

Change in Specifications

Product specifications and accessories may be changed at any time based on improvements and other reasons. It is our practice to change part numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the Product may be changed without any notice. When in doubt, special part numbers may be assigned to fix or establish key specifications for your application. Please consult with your Omron's representative at any time to confirm actual specifications of purchased Product.

Errors and Omissions

Information presented by Omron Companies has been checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical or proofreading errors or omissions.

Statement of security responsibilities for assumed use cases and against threats

OMRON SHALL NOT BE RESPONSIBLE AND/OR LIABLE FOR ANY LOSS, DAMAGE, OR EXPENSES DIRECTLY OR INDIRECTLY RESULTING FROM THE INFECTION OF OMRON PRODUCTS, ANY SOFTWARE INSTALLED THEREON OR ANY COMPUTER EQUIPMENT, COMPUTER PROGRAMS, NETWORKS, DATABASES OR OTHER PROPRIETARY MATERIAL CONNECTED THERETO BY DISTRIBUTED DENIAL OF SERVICE ATTACK, COMPUTER VIRUSES, OTHER TECHNOLOGICALLY HARMFUL MATERIAL AND/OR UNAUTHORIZED ACCESS.

It shall be the users sole responsibility to determine and use adequate measures and checkpoints to satisfy the users particular requirements for (i) antivirus protection, (ii) data input and output, (iii) maintaining a means for reconstruction of lost data, (iv) preventing Omron Products and/or software installed thereon from being infected with computer viruses and (v) protecting Omron Products from unauthorized access.

Safety Precautions

Refer to the following manuals for safety precautions.

- CS/CJ-series EtherNet/IP Units Operation Manual (Cat. No. W465)
- CX-Programmer Ver. 9. ☐ Operation Manual (Cat. No. W446)

Precautions for Safe Use

Refer to the following manuals for precautions for safe use.

- CS/CJ-series EtherNet/IP Units Operation Manual (Cat. No. W465)
- CX-Programmer Ver. 9. ☐ Operation Manual (Cat. No. W446)

Precautions for Correct Use

Refer to the following manuals for precautions for correct use.

- CS/CJ-series EtherNet/IP Units Operation Manual (Cat. No. W465)
- CX-Programmer Ver. 9. ☐ Operation Manual (Cat. No. W446)

When Updating Firmware

- When you update the firmware of CS1W/CJ1W-EIP21S EtherNet/IP Unit, the settings in the Unit are initialized.
- Do not turn OFF the power supply to PLC and computer during the firmware update of CS1W/ CJ1W-EIP21S EtherNet/IP Unit.
 - If the power supply to PLC is turned OFF, the Unit may not start normally the next time the power is turned ON.
- When you update the firmware of CS1W/CJ1W-EIP21S EtherNet/IP Unit, set the CPU Unit to PRO-GRAM mode.

Versions

The unit version of CS1W-EIP21S/CJ1W-EIP21S EtherNet/IP Unit and supporting versions of the CX-One and EIP21S Firmware Update Tool are shown below.

Unit version of CS1W-EIP21S/CJ1W-EIP21S	CX-One version	EIP21S Firmware Update Tool version
Ver.1.0	Ver.4.61	Ver.1.00


Related Manuals

The following table shows the manuals related to this product. Use these manuals for reference.

Manual name	Cat.No.	Model numbers	Application	Description
CX-Programmer	W446	CXONE-AL□□D-	Learning how to oper-	Describes the operating procedures of
Ver. 9. ☐ Operation		V4	ate the CX-Programm-	the CX-Programmer.
Manual			er, i.e., a programming	
			tool for Windows com-	
			puters.	
CX-One Setup	W463	CXONE-AL□□D-	Installing the CX-One	Provides an overview of the CX-One FA
Manual		V4/LT□□□-V4	software.	Integrated Tool Package and describes
				how to install the CX-One.
CS/CJ-series	W465	CS1W-EIP21	Learning how to use	Provides information on using an Ether-
EtherNet/IP [™] Units		CJ1W-EIP21	the EtherNet/IP Unit.	Net/IP Unit that is connected to a CS/CJ-
Operation Manual		CJ2H-CPU6□-EIP		series CPU Unit. The basic setup, tag
•		CJ2M-CPU3□		data links, and FINS communications are
		CS1W-EIP21S		described.
		CJ1W-EIP21S		

Revision History

A manual revision code appears as a suffix to the catalog number on the front and back covers of the manual.



Revision code	Date	Revised content
01	July 2023	Original production



Advance Preparations

This section describes advance preparations before performing the firmware update.

1-1	Preparations	1-2
1-2	EIP21S Firmware Update Tool	1-3
1-3	Obtaining Firmware Update Files	1-5
1-4	Precautions on Update	1-6

1-1 Preparations

This section describes the preparations that are required to update the firmware.

The following preparations are required when you update the firmware of CS1W-EIP21S/CJ1W-EIP21S (hereafter may be abbreviated as EIP21S Unit).

Item		
Required device	An EIP21S Unit to update the firmware	
	A CPU Unit and a Power Supply Unit to connect the EIP21S Unit	
	A firmware update file	
	EIP21S Firmware Update Tool	
	• EIP21S User Management Tool ^{*1}	
	• Computer*2	
User authentica-	A personnel with an administrator operation authority or a personnel who is planned to	
tion setting	have an administrator operation authority	
Backup ^{*3}	Simple backup function*4, or PLC Backup Tool	

^{*1.} Required to update the firmware of a new EIP21S Unit.

^{*4.} When you use the simple backup function, a Memory Card must be inserted in the CPU Unit.



Version Information

Refer to *Versions* on page 14 for the unit versions of EIP21S Unit and CX-One versions that support the EIP21S Firmware Update Tool.


Refer to the CS/CJ-series EtherNet/IP Units Operation Manual (Cat. No. W465) for other versions such as CX-Programmer that support the EIP21S Unit.

^{*2.} Use a computer with an operating system version of Windows 10 1803 or later.

^{*3.} Required if you want to reuse the settings in the EIP21S Unit.

1-2 EIP21S Firmware Update Tool

This section describes the EIP21S Firmware Update Tool.



Letter	Name	Description
(a)	Tool menu	Menu of this tool.
(b)	Communication Settings	Enter the IP address.
(c)	Firmware	Select the firmware update file, then the firmware information is displayed.
(d)	Update status	Displays the status while updating.
(e)	Exit Button	Exits from this tool.
(f)	Status bar	Displays various information.
(g)	Execute Update Button	Performs the update.

Tool Menu

This section describes the tool menu of the EIP21S Firmware Update Tool.

Category	Menu name	Description
File	Exit	Exits from this tool.
Help	Version Information	Displays the version information of this tool.

Communication Settings

Enter the IP address of the EIP21S Unit to connect to, then press the **Connect** Button to connect online.



Additional Information

You cannot edit the IP address while online.

Firmware

Click the **Select File** Button and select the firmware update file to update, then the firmware information is displayed.

Update Status

Displays the status during update.

Status Bar

Displays offline and online status, user name, and unit version, etc.

1-3 Obtaining Firmware Update Files

Download the firmware update file by using an Internet browser. Save the downloaded firmware update file in any folder.

Note For the URL to download the file, contact your OMRON representative.

The firmware update file name depends on the unit version for firmware update. For example, if the unit version for firmware update is version 3.21, the name of the firmware update file is as follows.

Firmware update file name | EIP21S_0321.sfm

1-4 Precautions on Update

This section describes the precautions on updating the firmware.

- When you update the firmware, use a computer with an operating system version of Windows 10 1803 or later. Secure communications cannot be performed on a computer with a version earlier than Windows 10 1803.
- When you update the firmware, set the CPU unit to PROGRAM mode.
 In addition, do not set the CPU unit to RUN mode while the Firmware Update Mode is ON.
- When you update the firmware, make sure that the EIP21S Unit is visible.
 If an error occurs during firmware update, you need to check the indicators on EIP21S Unit.
- Updating firmware initializes the existing various settings in the Unit shown below.
 - a) Special Unit settings, tag data link settings, and user authentication settings
 - b) Operation log

Therefore, if you are updating an operating EIP21S Unit, you must back up the setting data of EIP21S Unit using the simple backup function or the PLC Backup Tool.

- Do not perform the following operations while updating, as the EIP21S Unit may fail to start.
 - a) Disconnect the connected communications cables.
 - b) Turn off the power supply to CPU Unit or computer.
 - c) Exit the EIP21S Firmware Update Tool.
- You need to turn OFF and ON the power supply to EIP21S Unit after you update the firmware.



Performing Firmware Update

This section describes the procedures to update the firmware and how to perform it.

2-1	Work	kflow	2-2
	2-1-1	Reusing the Existing Various Settings	2-2
	2-1-2	Updating a New EIP21S Unit	2-3
2-2	Perf	orming Update	2-4
2-3	Oper	rations after Update	2-8

2-1 Workflow

This section describes an overview of the firmware update procedures.

The procedures differ depending on whether the existing various settings in the EIP21S Unit are reused after firmware update or a new EIP21S Unit that is not yet configured is updated.


The various settings in the EIP21S Unit are as follows.

- Special Unit settings
- · Tag data link settings
- · User authentication settings

When you want to reuse the existing various settings, use the simple backup function or the PLC Backup Tool to perform backup and restore.

When you update a new EIP21S Unit that is not yet configured, you do not need to back up the settings, but you must register the first administrator with the EIP21S User Management Tool.

2-1-1 Reusing the Existing Various Settings



- *1. Refer to 1-3 Obtaining Firmware Update Files on page 1-5 for downloading the firmware update file.
- *2. If the Unit is already in PROGRAM mode, no change is required.


- *3. Refer to *Maintenance and Unit Replacement* in the *CS/CJ-series EtherNet/IP Units Operation Manual (Cat. No. W465)* for information on how to operate backup and restore.
- *4. Refer to 2-2 Performing Update on page 2-4.
- *5. This procedure is necessary when backup is performed by the PLC Backup Tool.

 This procedure is not necessary if the backup was performed by the simple backup function.

 Refer to the CS/CJ-series EtherNet/IP Units Operation Manual (Cat. No. W465) and CX-Programmer Ver.

 9. \(\subseteq \text{ Operation Manual (Cat. No. W446)} \) for information on user authentication and tool operation using the EIP21S User Management Tool.

2-1-2 Updating a New EIP21S Unit



- *1. Refer to 1-3 Obtaining Firmware Update Files on page 1-5 for downloading the firmware update file.
- *2. Refer to the CS/CJ-series EtherNet/IP Units Operation Manual (Cat. No. W465) and CX-Programmer Ver. 9. ☐ Operation Manual (Cat. No. W446) for information on user authentication and tool operation using the EIP21S User Management Tool.
- *3. Refer to 2-2 Performing Update on page 2-4.

2-2 Performing Update

The EIP21S Firmware Update Tool must be connected directly to the EIP21S Unit.

- 1 Connect the EtherNet/IP port of EIP21S Unit and the computer.
- Select All Programs OMRON CX-One from the Start Menu of the computer, then double-click the EIP21S Firmware Update Tool in the EIP21S Tools folder.
 The EIP21S Firmware Update Tool starts.
- 3 In IP Address in the Communication Settings, enter the IP address of the EIP21S Unit to connect to, and click the Connect Button.

The Communication Settings view is shown below.



4 Enter the user name and password of the administrator to authenticate the user.



Only a user with administrator operation authority can place the tool online.

The following dialog box is displayed if the user authentication is successful, then click the **OK** Button.




5 Select the firmware update file.


The Firmware view is shown below.




6 Click the **Execute Update** Button to execute the firmware update.



After clicking the **Execute Update** Button, a warning dialog box for backup confirmation is displayed.



- · Click Yes to continue the update.
- · Click No to cancel the update.
- If you continue the update, the unit versions for firmware update before and after the update are displayed in the dialog box.



- · Click Yes to continue the update.
- Click No to cancel the update.



Additional Information

If the PLC is in RUN mode, the following warning message is displayed when the above update is continued.



- Click Yes to change the PLC to PROGRAM mode and continue the update.
- Click No to avoid changing the PLC from RUN mode and cancel the update.
- 8 If you continue the update, the update status displays the message of progressing update.






Precautions for Correct Use

Do not turn OFF the power supply to the CPU Unit or the computer while updating, doing so may prevent the EIP21S Unit to start.

When the firmware update is completed normally, a dialog box with messages of successful update and instruction to turn OFF and ON the power to PLC are displayed.



- **9** Click the **OK** Button to go offline.
- ${f 10}$ Click the ${f Exit}$ Button to exit from the EIP21S Firmware Update Tool.



Additional Information

If you want to continue to update the firmware of the second and subsequent EIP21S Units, go back to step 1 without exiting from the EIP21S Firmware Update Tool.

11 Turn OFF and ON the CPU Unit power.

The firmware update is completed with the above.

2-3 Operations after Update

After the firmware update is complete, restore the settings if you want to reuse them.

Refer to *Maintenance and Unit Replacement* in the *CS/CJ-series EtherNet/IP Units Operation Manual (Cat. No. W465)* for information on how to operate restore.

Refer to *Installation and Initial Setup* in the *CS/CJ-series EtherNet/IP Units Operation Manual (Cat. No. W465)* for information on setting up a new Unit.



Troubleshooting

This section describes troubleshooting by checking the EIP21S Firmware Update Tool and the indicators on EIP21S Unit.

3-1	Chec	king the EIP21S Firmware Update Tool	3-2
3-2	Chec	cking the Indicators on EIP21S Unit	3-4
	3-2-1	Errors during Update	3-5
		Errors during Restart after Undate	

3-1 Checking the EIP21S Firmware Update Tool

The table below describes troubleshooting problems indicated by the messages from the EIP21S Firmware Update Tool.

Error	Cause	Countermeasure
Invalid up-	The file was not obtained from the official OMRON	Obtain an update file again from the official OM-
date file	route.	RON route.
	The update file is corrupted.	
Unable to up-	The user is trying to update the EIP21S Unit with a	Use the EIP21S Firmware Update Tool which sup-
date	unit version not supported by the EIP21S Firmware	port the unit version.
	Update Tool.	
	The update file cannot be applied to the EIP21S Unit	Replace with an EIP21S Unit with an applicable
	which the user tries to update.	unit version.
Communica-	The following error occurred in the CPU Unit.	Check the error in the CPU Unit, take corrective
tions error	I/O bus error	action, and then execute the update.
	CPU Unit WDT error	
	A communications error with the EIP21S Unit occur-	Check the following and take corrective action.
	red.	Communication cable disconnection, looseness,
		and poor contact
		Noise
Update failed	An error occurred in the EIP21S Unit during update.	Check the error of the EIP21S Unit and take cor-
-		rective action. *1

^{*1.} Refer to 3-2-1 Errors during Update on page 3-5 for detail.

Errors in Connecting the EIP21S Firmware Update Tool

The table below describes troubleshooting problems that occur when connecting the EIP21S Firmware Update Tool and an EIP21S Unit.

Error	Setting item factor	Cause	Countermeasure
EIP21S Firmware Update Tool indi- cated a timeout when online con- nection was exe- cuted.	IP filter set- tings in the IP packet filter settings	The IP address of the computer is not allowed in the source IP.	 When IP address setting of the computer is incorrect Change the IP address of the computer to one allowed by the IP packet filter. When the setting in the EIP21S Unit is incorrect Connect the CX-Programmer online to the USB/serial port of the CPU Unit to which the EIP21S Unit is mounted and allow the IP of the computer.
seti IP p	Protocol filter settings in the IP packet filter settings	TCP443 is not allowed for the destination port.	Connect the CX-Programmer online to the USB/serial port of the CPU Unit to which the EIP21S Unit is mounted and allow the destination port TCP443.
		A computer with an operating system version earlier than Windows 10 1803 is used.	Update the operating system version of the computer to Windows 10 1803 or later.


Error	Setting item factor	Cause	Countermeasure
A user authentication error occurred on the User Authentication Dialog Box.	User authentication settings	The values entered are different from the user name and password that are set for the EIP21S Unit.	Enter the correct user name and password that are set for the EIP21S Unit. If you do not know your user name or password, request your administrator to add an account or reset your password.
		Password has expired.	Change your password.

3-2 Checking the Indicators on EIP21S Unit

This section describes the status and error indications by the operation status indicators and 7-segment display on the EIP21S Unit.

Checking the Operation Status Indicators

The operating statuses of EIP21S Unit that are indicated by the operation status indicators are shown as below.






*1. Operation status indicators


MS indicator	NS indicator	Description
Not lit	Not lit	The power is not on.
Flashing green	Not lit	The EIP21S Unit is in firmware update mode.
Lit green	Not lit	The firmware update is in progress.
Lit green	Lit green	The firmware update was completed normally.
Lit red	Not lit	An error occurred during the firmware update. *1

^{*1.} An error code is displayed on the 7-segment display. Refer to *Checking the Seven-Segment Display* on page 3-4 for details.

Checking the Seven-Segment Display

The operating statuses of EIP21S Unit that are indicated by the 7-segment display are shown as below.






*1. 7-segment display

Status	7-segment display
Default	

Status	7-segment display
Firmware update mode	
Firmware update in progress	The display pattern switches every 100 ms.
Completed normally	
When an error occurred	Displays the error code as a two-digit number. *1 Example: When an error code "01" occurred

^{*1.} Dot (.) is always not lit.


The indicator display patterns of number are as follows.



3-2-1 Errors during Update

This section describes troubleshooting problems that occur during firmware update.

Errors during update are displayed on the operation status indicators and 7-segment display of the EIP21S Unit.



- *1. Operation status indicators
- *2. 7-segment display

Operation status indicators		7-seg-	Decemention	Cause	Unit opera-		
MS indi- cator	NS indi- cator	ment display	Description	Cause	tion	Countermeasure	
Lit red	Not lit	01	Invalid update data	The data for update that was transferred from the EIP21S Firmware Update Tool is invalid.	Operation stop*1	Execute the update again after turning the power OFF and ON. If this error persists, it may be due to noise. Implement noise countermeasures.	
Lit red	Not lit	02	Firmware overwrite failure	The hardware of EIP21S Unit is faulty.	Operation stop*1	Replace the EIP21S Unit.	
Lit red	Not lit	03	Firmware overwrite failure	The hardware of EIP21S Unit is faulty.	Operation stop*1	Replace the EIP21S Unit.	
Lit red	Not lit	04	Firmware overwrite failure	The hardware of EIP21S Unit is faulty.	Operation stop*1	Replace the EIP21S Unit.	
Lit red	Not lit	Not lit	Unit error	An error occurred in the EIP21S Unit.	Operation stop	Execute the firmware update again after turning the power OFF and ON. If the firmware update cannot be executed, replace the EIP21S Unit.	

^{*1.} The bit 12 Firmware Update Mode in Unit Status 2 turns ON, and the bit 13 Firmware Update Executing turns OFF.

3-2-2 Errors during Restart after Update

This section describes troubleshooting problems that occur during restart after the firmware was updated.


Errors during restart are displayed on the operation status indicators and 7-segment display of the EIP21S Unit.



- *1. Operation status indicators
- *2. 7-segment display

Operation status indicators		7-segment Descrip-		Cause	Unit opera-	Countermeas-	
MS indicator	NS indicator	display	tion	Cause	tion	ure	
Not lit	Not lit	Not lit	Cannot start	The firmware was damaged by turning off the power etc. while overwriting the firmware of the EIP21S Unit.	Operation stop	Replace the EIP21S Unit.	

3 Troubleshooting



Appendices

This section describes how to install the EIP21S Firmware Update Tool and the operation log.

A-1	Installing and Uninstalling the EIP21S Firmware Update Tool	A-2
A-2	Operation Log	A-3

A-1 Installing and Uninstalling the EIP21S Firmware Update Tool

CX-One version 4.61 or higher is required to install and uninstall the EIP21S Firmware Update Tool.

Refer to the CX-One Setup Manual (Cat. No. W463) for information on how to install and uninstall the software

A-2 Operation Log

The operation log function records important operations and results of users who connect the Support Software online using secure communications, along with information on the date and time, computer's IP address, and user name.

This section describes the operation log for online operation by the EIP21S Firmware Update Tool. Refer to the *CS/CJ-series EtherNet/IP Units Operation Manual (Cat. No. W465)* for details on the operation log function.

		Operation log					
Description	Operation target	Log code (hex)	Operation	Result*1	Attached Informa- tion	IP ad- dress	User- name
Online connection	EIP21S	02	Online Connection Started	Normal exit	None	*2	*3
End online con- nection.	EIP21S	55	Online Discon- nection	Normal exit	None	*2	*3
Change to PRO- GRAM mode	CPU	0A	PLC Operation Mode (PRO- GRAM)	Normal exit Abnormal exit Cancel	None	*2	*3
Update the firm- ware of EIP21S Unit.	EIP21S	54	Change EIP21S Firmware Update	Normal exit Abnormal exit	When successful Attached Information 1: Unit version after update Attached Information 2: Unit version before update	*2	*3

Normal exit indicates that all operations were completed normally.
 Abnormal exit indicates other than normal exit and cancel.


When the firmware update is completed normally, the operation log is initialized.

Therefore, only *Change EIP21S Firmware Update (54)* and *Online Disconnection (55)* are logged in the operation log.

Cancel indicates that operation was canceled by a command. *2. Records the IP address of the operated computer.

^{*3.} Records the user name of the operated user account.

Appendices



Index

Index

Numerics	update faile
7-segment display	update stat
A	
advance preparations1-2	
C	
cannot start	
<u>E</u>	
EIP21S Firmware Update Tool	
<u>F</u>	
Firmware	
Н	
how to install	
<u>I</u>	
invalid update data	
0	
operation log	
P	
precautions on update1-6	
s	
status bar1-4	
<u>T</u>	
tool menu1-3	
U	
unable to update	

update failed	3-2
update status	1-4

OMRON Corporation Industrial Automation Company

Kyoto, JAPAN Contact : www.ia.omron.com

Regional Headquarters

OMRON EUROPE B.V.

Wegalaan 67-69, 2132 JD Hoofddorp The Netherlands Tel: (31) 2356-81-300 Fax: (31) 2356-81-388

OMRON ASIA PACIFIC PTE. LTD.

438B Alexandra Road, #08-01/02 Alexandra Technopark, Singapore 119968 Tel: (65) 6835-3011 Fax: (65) 6835-2711 OMRON ELECTRONICS LLC

2895 Greenspoint Parkway, Suite 200 Hoffman Estates, IL 60169 U.S.A. Tel: (1) 847-843-7900 Fax: (1) 847-843-7787

OMRON (CHINA) CO., LTD.

Room 2211, Bank of China Tower, 200 Yin Cheng Zhong Road, PuDong New Area, Shanghai, 200120, China Tel: (86) 21-5037-2222 Fax: (86) 21-5037-2200 Authorized Distributor:

©OMRON Corporation 2023 All Rights Reserved. In the interest of product improvement, specifications are subject to change without notice.

Cat. No. W628-E1-01 0723