

**according to Directive 2014/68/EU
for a pressure equipment**

The manufacturer

4.5 KM, Huha Road,Xincheng District,

Hohhot 010051,Inner Mongolia, China

herewith declares, that the pressure equipment

Description:	Check Valve
Year of manufacture:	2023
Type-, Serial-, Identification-No:	MV-54, ID No. MV-23374
Chamber designation:	1
Min./ max. allowable pressure PS:	16 bar
Allowable max./min. temperature TS:	-25 / 180 °C
Volume V / DN:	DN65
Test pressure PT:	24 bar
Date of pressure test:	2023-12-10
Pressure test medium:	water
Fluid- fluid group	1

corresponds to the Pressure Equipment Directive 2014/68/EU

Applied conformity assessment procedures:	A2
Applied standards and technical specifications:	EN12516-1/-2
Other applied EC-Directives:	N.A

Engaged notified bodies:

Surveillance of the QS-System:	HOHHOT MONVA VALVE CO., LTD.
Examination / inspections / test during manufacturing:	HOHHOT MONVA VALVE CO., LTD.

EU-Design Examination Certificate.:	N.A
EU-Type Examination Certificate No.:	N.A
EU-Certificate of conformity No.:	Z-PRC-18-05-607692-001

呼和浩特市蒙瓦阀业有限公司
HOHHOT MONVA VALVE CO., LTD.
宗城辉

Hohhot,2023-12-10

Signature: