SIEMENS

Product data sheet

BD2A-400-TV JUNCTION UNIT T UNIT FRONTSIDE 160-400A

Similar to image

General technical details:		
product designation		T unit (junction unit) for BD2 busbar trunking system
Product-type designation	_	BD2A-400-TV
Operating current		
• for circuit 1 / at 50 Hz / for AC / rated value / maximum	А	400
• for circuit 1 / at 60 Hz / for AC / rated value / maximum	А	400
Resistance against the impulse current / at 690 V / rated value	kA	40
Short-time current resistance (Icw) / at 690 V		
 limited to 1 s / rated value 	kA	16
Imited to 0.1 s / rated value	kA	20
Operating frequency / rated value		
• minimum	Hz	50
• maximum	Hz	60
Operating voltage		
• at 50 Hz / at AC / rated value / maximum	V	690
• at 60 Hz / at AC / rated value / maximum	V	690
Insulation voltage		
• for AC / rated value	V	690
• for DC / rated value	V	800

Number of conductors		5	
Number of conductors / without PE	_	4	
Fire resistance class / for fire sealing	_	Nein	
Product component / fire sealing		No	
Mechanical design:			
Conductor cross section / of the (PE)N	mm²	205	
Type of mounting		ceiling / wall	
Width	mm	184	
Height	mm	360	
Color		light grey	
Busbar:			
Configuration of the busbars		L1,L2,L3,L3,N	
Material / of the busbar		aluminium	
Busway section:			
Design of the busbar box junction unit / flexible		No	
Length of the X-dimension / of the busbar box junction unit			
• minimum	m	0.55	
• maximum	m	0.55	
Length of the Y-dimension / of the busbar box junction unit			
• minimum	m	0.36	
• maximum	m	0.36	
Ambient conditions:			
Protection class IP		IP52	
Further information:			
Information- and Downloadcenter (Catalogs, Brochures,) http://www.siemens.com/lowvoltage/catalogs			
Global Industry Mall (Online ordering system) http://www.siemens.com/lowvoltage/mall			
Service&Support (Manuals, Certificates, Characteristics, FAQs, http://support.automation.siemens.com/WW/view/en/BVP:261800/all	.)		
Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams,)			

http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=BVP:261800

last change:

Apr 26, 2012