SIEMENS

Product data sheet 3RT1275-6AM36



VAC. CONTACTOR, 200KW/400V/AC-3 AC(40...60HZ)/DC OPERATION UC 200-220V AUXILIARY CONTACTS 2NO+2NC 3-POLE, SIZE S12 BAR CONNECTIONS CONVENT. OPERATING MECHANISM

General details:		
Product brand name		SIRIUS
product designation		power contactor
Size of the contactor		S12
Protection class IP / on the front		IP00
Degree of pollution		3
Installation altitude / at a height over sea level / maximum	m	2,000
Ambient temperature / during operating	°C	-25 +60
Active power loss / per conductor / typical	W	21
Item designation		
according to DIN EN 61346-2		Q
 according to DIN 40719 extendable after IEC 204-2 / according to IEC 750 		К
Mechanical operating cycles as operating time		
of the contactor / typical		10,000,000
of the contactor with added auxiliary switch block / typical		10,000,000
 of the contactor with added electronics-compatible auxiliary switch block / typical 		5,000,000

Number of NC contacts / for main contacts		0
Number of NO contacts / for main contacts		3
Operating current / at AC-1 / at 400 V / at 40 °C ambient temperature / rated value	A	610
Operating current / at AC-1 / at 400 V / at 60 °C ambient temperature / rated value	A	550
Operating current		
• at AC-3 / at 400 V / rated value	Α	400
Service power		
• at AC-1 / at 400 V / rated value	kW	362
• at AC-2 / at 400 V / rated value	kW	231
• at AC-3		
• at 400 V / rated value	kW	200
• at 500 V / rated value	kW	291
• at 690 V / rated value	kW	400

Control circuit:		
Design of activation		conventional
Design of the surge suppressor		with varistor
Type of voltage / of the controlled supply voltage		AC/DC
Control supply voltage frequency		
• 1 / rated value	Hz	40
• 2 / rated value	Hz	60
Control supply voltage / 1		
• for DC		
• initial rated value	V	200
• final rated value	V	220
• at 50 Hz / for AC		
• initial rated value	V	200
• final rated value	V	220
• at 60 Hz / for AC		
• initial rated value	V	200
• final rated value	V	220

Auxiliary circuit:		
Contact reliability / of the auxiliary contacts	1 faulty switching per 100 million (17 V, 1 mA)	
Number of NC contacts / for auxiliary contacts		
• instantaneous switching	2	
lagging switching	0	
Number of NO contacts / for auxiliary contacts		
• instantaneous switching	2	

• leading switching		0
Operating current / of the auxiliary contacts		
• at AC-12 / maximum	Α	10
• at AC-15		
• at 230 V	Α	6
• at 400 V	Α	3
• at DC-12		
• at 60 V	Α	6
• at 110 V	Α	3
• at 220 V	Α	1
• at DC-13		
• at 24 V	Α	10
• at 60 V	Α	2
• at 110 V	Α	1
• at 220 V	Α	0.3

Short-circuit:

Design of the fuse link	
• for short-circuit protection of the auxiliary switch / required	fuse gL/gG: 10 A
• for short-circuit protection of the main circuit	
 with type of assignment 1 / required 	fuse gL/gG: 800 A
 at type of coordination 2 / required 	fuse aL/aG: 800 A

Installation/mounting/dimensions:		
Type of mounting		screw fixing
series installation		Yes
Width	mm	145
Height	mm	210
Depth	mm	206
Distance, to be maintained, to earthed part / sidewards	mm	10

Connection type:	
Design of the electrical connection	
for main current circuit	screw-type terminals
• for auxiliary and control current circuit	screw-type terminals
Identification number and letter for switching elements	22 E

Certificates/approvals:

General Product Approval

Functional Safety / Safety of Machinery **Test Certificates**





ROSTEST



SUVA

Manufacturer

Shipping Approval

other





Manufacturer

other

Further information:

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/industrial-controls/catalogs

Industry Mall (Online ordering system)

http://www.siemens.com/industrial-controls/mall

CAx-Online-Generator


http://www.siemens.com/cax


Service&Support (Manuals, Certificates, Characteristics, FAQs,...)


 $\underline{\text{http://support.automation.siemens.com/WW/view/en/3RT1275-6AM36/all}}$


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3RT1275-6AM36









last change: Sep 30, 2011