SIEMENS

Product data sheet

3RT1054-3AB36



CONTACTOR,

55 KW / 400 V / AC-3 AC(40...60HZ)/DC OPERATION UC 23-26V AUXILIARY CONTACTS 2NO+2NC 3-POLE, SIZE S6 WITH BOX TERMINALS CONVENTIONAL OPERATING MECHAN. CAGE CLAMP CONNECTION

General technical data:				
product brand name		SIRIUS		
Size of the contactor		S6		
Protection class IP / on the front		IP00		
Degree of pollution		3		
Installation altitude / at a height over sea level / maximum	m	2,000		
Ambient temperature / during operating	°C	-25 +60		
Mechanical operating cycles as operating time				
of the contactor / typical		10,000,000		
of the contactor with added auxiliary switch block / typical		10,000,000		
 of the contactor with added electronics-compatible auxiliary switch block / typical 		5,000,000		
Main circuit:				
Number of NC contacts / for main contacts		0		
Number of NO contacts / for main contacts		3		
Operating current				
• at AC-1 / at 400 V				
• at 40 °C ambient temperature / rated value	А	160		
• at 60 °C ambient temperature / rated value	А	140		
• at AC-3 / at 400 V / rated value	А	115		

• at AC-4 / at 400 V / rated value	А	97
• with 1 current path / at DC-1		
• at 24 V / rated value	А	160
• at 110 V / rated value	А	18
• with 2 current paths in series / at DC-1		
• at 24 V / rated value	А	160
• at 110 V / rated value	А	160
• with 3 current paths in series / at DC-1		
• at 24 V / rated value	А	160
• at 110 V / rated value	А	160
• with 1 current path / at DC-3 / at DC-5		
• at 24 V / rated value	А	160
• at 110 V / rated value	А	2.5
• with 2 current paths in series / at DC-3 / at DC-5		
• at 24 V / rated value	А	160
• at 110 V / rated value	А	160
• with 3 current paths in series / at DC-3 / at DC-5		
• at 24 V / rated value	А	160
• at 110 V / rated value	А	160
Service power		
• at AC-2 / at 400 V / rated value	kW	64
• at AC-3 / at 400 V / rated value	kW	64
• at AC-4 / at 400 V / rated value	W	55,000


Control circuit:


Design of the surge suppressor		with varistor
Type of voltage / of the controlled supply voltage	-	AC/DC
Operating range factor control supply voltage rated value / of the magnet coil		
• at 50 Hz		
• for AC		0.8 1.1
• at 60 Hz		
• for AC		0.8 1.1
• for DC		0.8 1.1
Apparent pull-in power / of the solenoid / for AC	V·A	300
Apparent holding power / of the solenoid / for AC	V·A	5.8
Inductive power factor / with the pull-in power of the coil		0.9
Inductive power factor / with the pull-in power of the coil	_	0.8
Pull-in power / of the solenoid / for DC	W	360
Holding power / of the solenoid / for DC	W	5.2


Auxiliary circuit:		
Contact reliability / of the auxiliary contacts		1 faulty switching per 100 million (17 V, 1 mA)
Number of NC contacts / for auxiliary contacts / instantaneous switching		2
Number of NO contacts / for auxiliary contacts / instantaneous switching		2
Short-circuit:		
Design of the fuse link		
• for short-circuit protection of the auxiliary switch / required		fuse gL/gG: 10 A
for short-circuit protection of the main circuit		
with type of assignment 1 / required		fuse gL/gG: 355 A
• at type of coordination 2 / required		fuse gL/gG: 315 A
Installation/mounting/dimensions:		
Type of mounting		screw fixing
series installation		Yes
Width	mm	120
Height	mm	172
Depth	mm	170
Distance, to be maintained, to earthed part / sidewards	mm	10
Connection type:		
Design of the electrical connection		
• for main current circuit		screw-type terminals
• for auxiliary and control current circuit		Cage Clamp terminals
Type of the connectable conductor cross-section		
• for main contacts		
• stranded		max. 2x 70 mm ²
• finely stranded		
with conductor end processing		max. 1x 50, 1x 70 mm²
without conductor final cutting		max. 1x 50, 1x 70 mm ²
for AWG conductors / for main contacts		2x 1/0
 for auxiliary contacts 		
for auxiliary contactssolid		2x (0.25 2.5 mm²)
		2x (0.25 2.5 mm²)
• solid		2x (0.25 2.5 mm²) 2x (0.25 1.5 mm²)
solid finely stranded		

Certificates/approvals:

General Product Ap	proval				
	(SA)	EAC	GOST	KETI	
Functional Safety / Safety of Machinery	Declaration of Conformity	Test Certificates			
Type Examination	CE EG-Konf.	Special Test Certificate			
Shipping Approval					
ABS	ŮŇ DNV DNV	GL	RMRS		
other					
Confirmation	other	Environmental Confirmations			
Further information	ו:				
Information- and Downloadcenter (Catalogs, Brochures,) http://www.siemens.com/industrial-controls/catalogs					
Industry Mall (Online http://www.siemens.co		all			
Cax online generator: http://www.siemens.co					
	Service&Support (Manuals, Certificates, Characteristics, FAQs,) http://support.automation.siemens.com/WW/view/en/3RT1054-3AB36/all				
mage database (product images, 2D dimension drawings, 3D models, device circuit diagrams,) http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3RT1054-3AB36					







last change:

Aug 12, 2013

φ