

Similar to image

CIRCUIT BREAKER 400V 10KA, 4-POLE, A,
32A, D=70MM

Technical data:		
Overvoltage class		3
type of voltage		AC/DC
Tripping characteristic class		A
Degree of pollution		3
Mounting depth	mm	70
Energy limiting class		3
Number of poles		4
Number of pitch units for width		4
Product function / n-switching		No
Supply voltage frequency / rated value	Hz	50
Switching capacity current / in accordance with IEC 60947-2 / rated value	kA	20
Breaking capacity current / acc. to EN 60898 / rated value	kA	10
Supply voltage / for AC / rated value	V	400
Current / for AC / rated value	A	32
Protection class IP		IP20, with connected conductors
Product extension / can be installed / supplementary device		Yes
power loss		-
Operational voltage Um		-
rated current In		-
Rated make-break capacity Icn		-
Rated service short-circuit breaking capacity Ics		-
Rated ultimate short-circuit breaking capacity Icu		-
Tripping characteristics Number		-
Tripping characteristic/-class Conventional tripping current I2, (x In)		-
rated current In IEC, DIN/VDE		-
Tripping characteristic/-class Test current I4, hold (x In)		-
rated current In / IEC, DIN/VDE		
• at 30 Cel	A	32
• at 40 Cel	A	30.72
• at 45 Cel	A	30.08

- at 50 Cel
- at 55 Cel
- at 60 Cel

A	29.44
A	28.48
A	27.84

Resistance against shock / according to IEC 60068-2-27

150m/s² at 11ms half-sine

Certificates/approvals:

General Product Approval

other



CQC

[ROSTEST](#)



VDE

[other](#)

Further information:

Information- and Downloadcenter (Catalogs, Brochures,...)

<http://www.siemens.com/lowvoltage/catalogs>

Industry Mall (Online ordering system)

<http://www.siemens.com/lowvoltage/mall>

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)



<http://support.automation.siemens.com/WW/view/en/5SY4432-5/all>


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=5SY4432-5

CAX-Online-Generator

<http://www.siemens.com/cax>





last change:

Nov 3, 2011