



The Public Health and Safety Organization

NSF Product and Service Listings

These NSF Official Listings are current as of **Thursday, September 20, 2018** at 12:15 a.m. Eastern Time. Please [contact NSF International](#) to confirm the status of any Listing, report errors, or make suggestions.

Alert: NSF is concerned about fraudulent downloading and manipulation of website text. Always confirm this information by clicking on the below link for the most accurate information: <http://info.nsf.org/Certified/PwsComponents/Listings.asp?Company=4C630&Standard=061&>

NSF/ANSI 61 Drinking Water System Components - Health Effects

NOTE: Unless otherwise indicated for Materials, Certification is only for the Water Contact Material shown in the Listing. Click here for a list of [Abbreviations used in these Listings](#). Click here for the definitions of [Water Contact Temperatures denoted in these Listings](#).

ITW Spraytec Nordic ApS

Priorsvej 36
8600 Silkeborg
Denmark
45 86 82 64 44

Facility : # 1 Europe

Joining and Sealing Materials

Water

Water

Trade Designation	Size	Contact Temp	Contact Material
Adhesives			
Kemlock AL-03	>= 1/2"	C. HOT	ADH
Kemlock AL-38	>= 1/2"	C. HOT	ADH
Kemlock AP-74[1]	>= 1/2"	C. HOT	ADH
Kemlock AS-43WM[1]	>= 1/2"	C. HOT	ADH
Kemlock AS-70	>= 1/2"	C. HOT	ADH
Kemlock AS-75	>= 1/2"	C. HOT	ADH

[1] Product requires a minimum 24 hour cure.

Sealants			
Kemlock AP-73	>= 1/2"	C. HOT	SLT
Thread Compounds			
Kemlock AS-70	>= 1/2"	C. HOT	TC
Kemlock AT-72	>= 1/2"	C. HOT	TC
Kemlock AT-77[2]	>= 1/2"	C. HOT	TC

[2] Certification is based on a minimum cure of 72 hours at 75°F.

Number of matching Manufacturers is 1

Number of matching Products is 10

Processing time was 0 seconds