

Quality, Environment and Safety

Manufacturers Declaration Certificate of Conformity

The below listed national and international directives/standards were observed during the design of the VLT® MicroDrive FC-051

| Directive/standard/norm | Description |
|--|---|
| 73/23/ECC (EN 61800-5-1 as preferred safety standard) | LOW VOLTAGE DIRECTIVE |
| EN 61800-5-1 Part 5-1: | Adjustable speed electrical power drive systems - Safety requirements – Electrical, thermal and energy |
| EN 50178 | Electronic equipment for use in power installations Visual inspections Requirements for protections against electric shock Protection against direct contact Protection by means of enclosures and barriers Distances Protection by means of protective impedance Protection by using limited voltage in control circuits Protection with regard to indirect contact Insulation between live parts and exposed conductive parts Protective bonding Solid insulation, insulation of circuits Clearances and creepage distances Constructive measures Requirements for EE in installations with regard to protection against electric shock Protection with regard to direct contact Connection of EE with protective separation Protection with regard to indirect contact Electrical connections Marking, identification, documentation Dry heat test Damp heat steady state Tumble test Vibration, sinusoidal Non-accessibility test Enclosure test Impulse voltage test AC or DC voltage test Partial discharge test Emission of EMC disturbances Immunity from EMC disturbances Short-circuit withstand capability |

Quality, Environment and Safety

89/336/EEC (EN61800-3/IEC61800-3 as preferred standard)

EN61800-3/IEC61800-3

EN/IEC61600-6-3/4

EN 55011

EN 55011

EN 55011

EN/IEC61600-6-1/2

EN 61800-3/ IEC61800-3

EN 61000-4-2 (IEC 61000-4-2)

EN 61000-4-3 (IEC 61000-4-3)

EN 61000-4-4 (IEC 61000-4-4)

EN 61000-4-5 (IEC 61000-4-5)

EN 61000-4-6 (IEC 61000-4-6)

EN 61800-3/ (IEC 61800-3)

IEC 61000-2-4

IEC 60146-1-1

IEC 61000-2-4

IEC/EN61000-4-11

IEC 61000-2-4

IEC 61000-2-4

EN 61800-3/ (IEC 61000-3)

EN 61000-3-2 (IEC 61000-3-2)

EN 61000-3-12 (IEC 61000-3-12)

UL 508c

Enclosure Construction

section 6 (UL 50)

Environmental Rating Related Enclosure Construction

section 7 (UL 50)

section 8 (UL 50)

Environmental Rating Related Enclosure Performance

section 9 (UL 50)

Non-Environmental Rating Related Enclosure Performance

section 10

section 11

Instructions and Marking Pertaining to Enclosures

section 12

section 13

Device Construction

section 14

section 15

section 16

section 17

section 18

section 19

section 20

section 21

section 22

section 23

section 24

EMC DIRECTIVE

Emission PDS Product Standard

Emission- public/industry

Conducted Class A-1

Conducted Class B-1

Radiated Class A-1

Immunity- public/industry

Immunity Industri

Electrostatic discharge (ESD)

Electromagnetic radiated field, A.M. modulated

Burst transients

Surge transients

RF field, common mode

Low frequency immunity

Harmonics

Commutation notches

Voltage variations and fluctuations

Voltage dips and short interruptions

Voltage unbalance

Frequency variations

Low frequency emission

Harmonics ($I \leq 16A$)

Harmonics ($I > 16A$)

Safety for Power Conversion Equipment

Frames and Enclosure

General

Protection against corrosion

General

General
Securement of snap-on cover test

Permanence of marking
details

General

Protection against corrosion

Provisions for Mounting

Insulation Material

Means for switching

Live Parts

Drive Protection

Capacitors

Fuseholders

Internal wiring

External Interconnections

Quality, Environment and Safety

section 25
section 26
section 27
section 29
section 30
section 32
section 35
section 36 (UL840)
section 37
section 38

Transformers
Blower Motors
Supply Connections
Risk of Electric shock
Risk of Fire
Secondary Circuits
Isolation Devices
Spacings
Grounding
Accessories

Device Performance

section 39
UL 508c
section 40
section 41
section 41.1
section 41.3
section 41.4
section 41.6
section 42
section 43
section 44
section 45
section 48
section 50
section 51
section 54

General
Safety for Power Conversion Equipment
Temperature
Abnormal operation tests
General
Single phasing
Inoperative blower motor
Current limiting control
Full-load motor-running current tables
Solid state motor overload protection test
Dielectric voltage withstand test
Short circuit test-standard fault currents
Transient-voltage-surge suppression test
Brake down of components test
Terminal torque test
Rating

Device Marking

section 55
section 56
section 57
section 60
section 61
section 62
section 63

General
Overload, Over current, Over speed
Branch circuit short circuit protection
Wiring terminal markings
Cautionary markings
Instructions and markings pertaining to accessories
Marking location

Manufacturing and production line test

section 64

Circuit functionality evaluation

CAN/CSA-C22.2 No. 14-95 (approved by UL)
CAN/CSA-22.2 No. 0.15-95

Industrial Control Equipment
Adhesive Labels

Quality, Environment and Safety

Miscellaneous standards/norms:

Danfoss Corporate Guideline: 500B0430
and ISTA, procedure 1A and 1

Danfoss Corporate Guideline: 500B0432,

Sinus Vibration, curve V (IEC 68-2-6, test Fc)

Random vibration, curve E / F

IEC 60068-2-64

VDE 0160

EN 50178 (section 5.2.11)

EN50178 (section 6.1, table 7)(IEC 721-3-3)

EN 50178 (section 6.1, table 7)(IEC 721-3-1)

EN 50178 (section 6.1, table 7)(IEC 721-3-2)

VBG-4

Guideline for Transportation test
(Packaging)

Guideline for Vibration test

Vibration, Sinus

Vibration, Random

Vibration, random, broad-band

Mains transients test pulse, class 1/2

Leakage current and fault current

Temperature (Class 3K3), Relative humidity
(Class 3K3), Air pressure (Class 3K3)

In Storage: Temperature (Class 1K4), Relative
humidity (Class 1K3), Air pressure (Class 1K4)

During transportation: Temperature (Class 2K3),
Relative humidity (Class 2K3), Air pressure
(Class 2K3)

Direct touching

The conditions for observing the above mentioned directives/standards/norms, see the Operation Instruction or Design Guide for the specific product series.

Issued by:



Lars Erik Donau

Quality Systems Manager