

Declaration of Conformity:

Cable Distribution Cabinet type KSE Series

Manufacturer:

Name: Triax Systems

Address: Bjørnkærvej 3
DK 8783 Hornsyld

Country: Denmark

Telephone: +45 7020 8081
Web-page: www.triaxsystems.dk

Description:

The KSE is a modular Cable Distribution Cabinet, design for energy distribution in public electricity supply networks. This Declaration of Conformity covers Cable Distribution Cabinet type KSE 300909 -302109 with 630 A Copper busbar system.

Declaration of Conformity:

Triax Systems confirms that the products are in conformity with directive 2006/95/EC and consequently has the ability to carry the CE-mark.

Relevant harmonised standards:

Low-Voltage Switchgear Assemblies:	EN 60439-1
Low-Voltage Switchgear Assemblies:	EN 60439-5
Empty enclosure for low-voltage switchgear and controlgear assemblies:	IEC/EN 62208
Verification of degree of protection against external mechanical impact (IK10):	IEC/EN 62282
Degrees of protection provided by enclosures (IP 34D):	IEC/EN 60529

Further tests carried out:

Heating test, busbar:	EN 60269-1
Cycling test, busbar:	HD 60629-3-1 & HD 60269-2-1
Salt spray (fog), enclosure	ISO 7253
Salt spray (fog), busbar:	ISO 9227

This document is only valid with the signature of the person there are responsible for CE-marking by Triax Systems.

Date:

Keld Nebel Jørgensen, Quality Manager.

Hornsyld, 05.08.2014

Signature

